

Memo No:-

Date:-

**Subject : Bacteriological Examination Report of Water Sample**

Sample ID:	REW/00361/4/2024	<b>Sample Details</b>	<b>Date &amp; Time</b>
Sample Classification:	Private	Collected By	VIVEKANAD PUBL...,9416117772
Sender:	VIVEKANAD PUBLIC SCHOOL30208	Collection Date	19/04/2024 at 10:00
Location :-	, VILLAGE LAKHNAUR PO BHUDPUR DISTT REWARI	Received at lab	19/04/2024 at 12:57
Latitude :-	76.561043	Tested at Lab	22/04/2024
Longitude :-	28.226800		

**Test Result (As Per BIS 10500 :2012)**

S.No.	Tested Parameter	Result	Requirement (Acceptable Limit)	Protocol Used
1	Total Coliform per 100 ml	0	Shall not be detectable in any 100 ml sample	IS 15185:2016/ APHA 9221C: 2017

**Remarks :-**

- \* The Results Given above are related to the sample as received and tested in REWARI lab.
- \* The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- \* The test report can't be used for any publicity or any legal purpose.
- \* Reliability of water sample sample lies with sender/collector of water sample.
- \* To check the sample report online Scan the QR Code below.

Water Sample has been found "**CONFORMING**" to Limits set in BIS10500:2012 for the tested parameters.  
Based on the tested parameters,the water sample is found "**POTABLE**"



  
DILBAG SINGH,CHEMIST  
PUBLIC HEALTH ENGINEERING DEPARTMENT  
DISTRICT WATER TESTING LABORATORY,REWARI  
email:-chemist.rewari@phedharyana.gov.in

-----End of Report-----



## सैनीटेशन प्रमाण पत्र


क्रमांक:-डी0एच0ओ0-2024 / 105

दिनांक:- 18/4/2024

प्रमाणित किया जाता है कि विवेकानन्द पब्लिक स्कूल लाखनौर जिला रेवाडी हरियाणा का निरीक्षण किया गया तथा पाया गया कि विधालय में पीने का पानी, शौचालय का उचित प्रबन्ध है तथा वातावरण साफ एवं स्वच्छ है।

रेवाडी।

18/4/24

  
उप सिविल सर्जन  
P.C.M.S.  
कृते सिविल सर्जन रेवाडी  
For Civil Surgeon, Rewari